



Jim Doyle, Governor  
Jack L. Fischer, A.I.A., Secretary

January 9, 2007 **RE-ISSUED 7/25/2008**

POLYLOK, INC.  
DON SMYTH  
173 CHURCH  
YALESVILLE CT 06492

**Re: Description: SEWAGE TANK COVERS, LIDS, RISERS**  
Manufacturer: POLYLOK, INC.  
Product Name: SEPTIC TANK RISER  
Model Number(s): 20" RISER AND COVER (3009 AND 3009-RC)  
24" RISER AND COVER (3008 AND 3008-RC)  
Product File No: 20070001

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- Riser covers must only have tamper proof screws installed.

This approval supersedes the approval issued on 4/2/2002 under product file number 20010306. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20010306.

**TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TANK COVERS, LIDS AND RISERS (STCOVER); SEE ALSO [http://commerce.wi.gov/php/sb-ppalopp/prodcode\\_alpha\\_list.php](http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php).**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov